



199 Fire Tower Drive
Tonawanda, NY USA

Phone: (716) 629-3800
FAX: (716) 693-9162



Certificate of Compliance

The following models, with the NX option:

510 and 520

Were evaluated by:

CSA International
8501 E. Pleasant Valley Road
Cleveland, OH 44131

They were found to comply with the following Canadian Regulations:

CAN/CSA Standard C22.2 No. 0: M91 (Reaffirmed 2006)
CSA Standard C22.2 No. 142: M1987 (Reaffirmed 2004)
CAN/CSA Standard C22.2 No. 157: 92 (Reaffirmed 2006)
CAN/CSA E60079-0: 02
CAN/CSA E60079-11: 02 (Reaffirmed 2006)

This shows that these products are Intrinsically Safe and can be used in the following Hazardous Locations:

Class I, Division 1, Groups A, B, C, and D

Ex ia IIC

Temperature Code T4 at Tamb = 80°C

Temperature Code T5 at Tamb = 40°C

When installed per the following drawings:

[CD0666](#)

This is specified on the CSA Certificate of Compliance [1437390](#)

The products are marked with the CSA Mark and the above ratings

I declare that the above statements are factual.

4/9/21

Joel Neri
Viatran Quality/Approvals Manager

Date

98NX510COFC Rev. E